

EC Type-Examination Certificate



Reg.-No.: CE-2456-CN-1040

Product tested	Condensing boiler	Certificate holder	FERROLI Via Ritonda 78/A 37047 San Bonifacio (VR) Italy
Type designation	SILENT D 30 CONDENS SILENT D 30 CONDENS UNIT SILENT D 30 CONDENS SI UNIT SILENT D 30 CONDENS K 100 UNIT		
Codes and standards	DIN EN 303-1:2003-12 DIN EN 303-2:2003-12	DIN EN 304:2004-01	

The requirements of the Efficiency Directive 92/42/EEC for condensing boilers are fulfilled.

The issue of this certificate is based upon an examination, whose results are documented in Report No. K 0747 2016 B 04 dated 2016-12-21.

This certificate is valid only for products which are identical with the product tested. It becomes invalid at any change of the codes and standards forming the basis of testing for the intended application.

TÜVRheinland®

Genau. Richtig.

TÜV Rheinland Energy GmbH
Am Grauen Stein
51105 Köln

Köln, 2017-04-28

Notified Body for BED, NB 2456

Mario Reibold
Dipl.-Ing. Mario Reibold

Produkt-ID-Nummer: <i>Product-ID-Number</i>	CE-2456-CN-1040
---	------------------------

Technical data:

Type	Heat output [kW]	Fuel *)	Nominal power 100%		Partial load 30%	
			Pair of temperature 80°C/60°C		required	achieved
			required	achieved	required	achieved
SILENT D 30 CONDENS SILENT D 30 CONDENS UNIT SILENT D 30 CONDENS SI UNIT SILENT D 30 CONDENS K100 UNIT	15,6 – 28,5	P	89,7	97,1	89,7	103,7

*) Fuel: P = oil / G = gas