

EC Type-Examination Certificate



Reg.-No.: CE-2456-CN-1080

Product tested	Low temperature boiler	Certificate holder	FERROLI Via Ritonda 78/A 37047 San Bonifacio (VR) Italy
Type designation	GN4 BT3 6/130 GN4 BT3 7/170 GN4 BT3 8/210 GN4 BT3 9/250 GN4 BT3 10/300 GN4 BT3 11/350 GN4 BT3 12/400		
Codes and standards	DIN EN 303-1:2003-12 DIN EN 303-2:2003-12	DIN EN 304:2004-01	

The requirements of the Efficiency Directive 92/42/EEC for low temperature Boilers are fulfilled.

The issue of this certificate is based upon an examination, whose results are documented in Report No. K 0062 2012 B 12 dated 2012-12-28.

This certificate is valid only for products which are identical with the product tested. It becomes invalid at any change of the codes and standards forming the basis of testing for the intended application.

TÜVRheinland®

Genau. Richtig.

TÜV Rheinland Energy GmbH
Am Grauen Stein
51105 Köln

Köln, 2017-04-28

Notified Body for BED, NB 2456

Dipl.-Ing. Mario Reibold

Produkt-ID-Nummer: <i>Product-ID-Number</i>	CE-2456-CN-1080
---	------------------------

Technical data:

Type	Heat output [kW]	Fuel *)	Nominal power 100%		Partial load 30%	
			Pair of temperature 80°C/60°C			
			required **)	achieved	required **)	achieved
GN4 BT3 6/130	85-130	P	90,7	94,3	90,7	95,9
GN4 BT3 7/170	110-170	P	90,8	94,5	90,8	96,1
GN4 BT3 8/210	140-210	P	91,0	94,7	91,0	96,2
GN4 BT3 9/250	160-250	P	91,1	94,9	91,1	96,4
GN4 BT3 10/300	195-300	P	91,2	95,0	91,2	96,4
GN4 BT3 11/350	230-350	P	91,3	95,2	91,3	96,5
GN4 BT3 12/400	260-400	P	91,4	95,3	91,4	96,5

*) determined with light oil (P = oil / G = gas)