

EC Type-Examination Certificate



Reg.-No.: CE-2456-CP-1040

Product tested	Standard boiler	Certificate holder	FERROLI Via Ritonda 78/A 37047 San Bonifacio (VR) Italy
Type designation	PREXTHERM RSH 100 N PREXTHERM RSH 150 N PREXTHERM RSH 200 N PREXTHERM RSH 250 N PREXTHERM RSH 300 N PREXTHERM RSH 360 N		
Codes and standards	DIN EN 303-1:2003-12 DIN EN 303-2:2003-12	DIN EN 303-3:2010-10 DIN EN 304:2004-01	

The requirements of the Efficiency Directive 92/42/EEC for Standard Boilers are fulfilled.

The issue of this certificate is based upon an examination, whose results are documented in Report No. K 1214 2016 B 15 dated 2016-07-22.

This certificate is valid only for products which are identical with the product tested. It becomes invalid at any change of the codes and standards forming the basis of testing for the intended application.

TÜVRheinland®

Genau. Richtig.

TÜV Rheinland Energy GmbH
Am Grauen Stein
51105 Köln

Köln, 2017-05-29

Notified Body for BED, NB 2456

Dipl.-Ing. Mario Reibold

Product-ID-Number:	CE-2456-CP-1040
---------------------------	------------------------

Technical data:

Type	Heat output [kW]	Oil/Gas *)	Nominal power 100%		Partial load 30%	
			Pair of temperature 80°C/60°C		required	achieved
			required	achieved	required	achieved
PREXTERM RSH 100N	73-106	P/G	88,00	94,27	86,00	95,52
PREXTERM RSH 150N	104-159	P/G	88,35	94,52	86,53	95,77
PREXTERM RSH 200N	140-211	P/G	88,60	94,80	86,90	92,30
PREXTERM RSH 250N	176-263	P/G	88,80	95,02	87,19	96,02
PREXTERM RSH 300N	207-316	P/G	88,95	95,15	87,43	96,12
PREXTERM RSH 360N	248-378	P/G	89,11	95,37	87,67	96,37

*) determined with light oil (P = oil / G = gas)