



TÜVRheinland®

ZERTIFIKAT
CERTIFICATE

No.: 968/EL 860.00/12

Product tested	Burullus WDDM Phase VIII B High Integrity Pressure Protection System (HIPPS)	Certificate holder	Burullus Gas Company Building 1 Road 294 New Maadi - Cairo Egypt
Type designation	Design, Qualification and Safety Documentation of the WDDM Phase VIII B HIPPS, All-27000-00, Module No. 001	Manufacturer	Vetco Gray Controls 2, High Street, Nailsea Bristol United Kingdom
Codes and standards forming the basis of testing	IEC 61511-1:2003 + Corr. 1:2004 IEC 61508 Parts 1-7:2010 (in extracts)		
Intended application	Safeguard for protection against over-pressure. The design and configuration of the HIPPS complies with the requirements of IEC 61508 and IEC 61511 for SIL 3.		
Specific requirements	The instructions of the associated Installation and Operating Manual shall be considered. The recommendations for proof testing given by GE have to be followed strictly. Any change in type of used hardware modules, and changes in the application configuration requires a reconsideration of the whole system.		

The test report-no.: 968/EL 860.00/12 dated 2012-08-30 is an integral part of this certificate.

This certificate is valid only for products which are identical with the product tested. It becomes invalid at any change of the codes and standards forming the basis of testing for the intended application.

TÜV Rheinland Industrie Service GmbH
Bereich Automation
Funktionale Sicherheit
Am Grauen Stein, 51105 Köln

Köln, 2012-08-30

Certification Body for FS-Products

Dr.-Ing. Thorsten Gantevoort