



TÜVRheinland®

ZERTIFIKAT
CERTIFICATE

No.: 968/EZ 624.00/13

Product tested	Temperature Monitors	Certificate holder	Bently Nevada Inc. 1631 Bently Parkway South Minden, NV 89423 USA
Type designation	3500/60-AXX-B00, 3500/60-AXX-B01, 3500/61-AXX-B00, 3500/61-AXX-B01	Manufacturer	see certificate holder
Codes and standards forming the basis of testing	IEC 61508 Parts 1-7:2010 IEC 61131-2:2007		
Intended application	The 3500/60 and 3500/61 Temperature Monitors are designed for machinery protection application. The safety function of the 3500/60 and 3500/61 is to alert the temperature has exceeded the user-programmable alarm setpoint. The 3500/60 and 3500/61 are suitable for safety-related applications up to SIL 2 (IEC 61508).		
Specific requirements	For the use of the 3500/60 and 3500/61 Temperature Monitor the installation, operation and maintenance instructions (released by Bently Nevada Corp.) shall be considered.		
This certificate is valid until 2018-12-23.			



Functional Safety Type Approved

www.tuv.com
ID 0600000000

The issue of this certificate is based upon an examination, whose results are documented in report-no.: 968/EZ 624.00/13 dated 2013-12-23.

The holder of a valid licence certificate for the product tested is authorized to affix the test mark shown opposite to products, which are identical with the product tested.

TÜV Rheinland Industrie Service GmbH
Bereich Automation
Funktionale Sicherheit
Am Grauen Stein, 51105 Köln

Köln, 2013-12-23

Certification Body for FS-Products

Dipl.-Ing. Stephan Häb