

Certificate



Type Approved

www.tuv.com
ID 0004000000

No.: V 465.01/15

Product tested 3/2 way solenoid valve **Certificate holder** Asco Numatics
Industrielaan 21
3925 BD Scherpenzeel
The Netherlands

Type designation 326 series

Codes and standards IEC 61508 Parts 1-2 and 4-7:2010 IEC 61511 Parts 1-3:2004

Intended application Safety Function: Move into safe position (close or open) by spring force
The valves are suitable for use in a safety instrumented system up to SIL 2. Under consideration of the minimum required hardware fault tolerance HFT=1 the valves may be used in a redundant structure up to SIL 3.

Specific requirements The instructions of the associated Installation and Operating Manual shall be considered.

Summary of test results see back side of this certificate.

Valid until 2020-01-21

The issue of this certificate is based upon an examination, whose results are documented in Report No. V 465.01/15 dated 2015-01-21.

This certificate is valid only for products which are identical with the product tested. It becomes invalid at any change of the codes and standards forming the basis of testing for the intended application.

TÜV Rheinland Industrie Service GmbH

Bereich Automation
Funktionale Sicherheit

Am Grauen Stein, 51105 Köln

Köln, 2015-01-21

Certification Body for FS-Products

Dipl.-Ing. Stephan Häb

www.fs-products.com
www.tuv.com

TÜVRheinland[®]
Precisely Right.

Manufacturer / production sites	ASCO Joucomatic 53 rue de Beauce 28110 Lucé France	ASCO Joucomatic SP. z.o.o. UL Kurczaki 132 PL 93-331 Łódź Poland
	ASCO Controls B.V. Industrielaan 21 3925 BD Scherpenzeel The Netherlands	ASCO India Limited 57, Kunrathur Main Road Gerugambakkam. Porur, Chennai-602102 India
Product tested	soleneoid valve 326	

Device-Specific Values

Probability of Dangerous Failure on Demand	PFD_{spec}	1.81 E-04
Test Interval	T_i	1 a
Confidence Level	$1-\alpha$	95 %
Safe Failure Fraction ^(see note)	SFF	95 %
Hardware Fault Tolerance	HFT	0
Diagnostic Coverage	DC	0 %
Type of Sub System		Type A
Mode of Operation		Low Demand
Proof Test Coverage	PTC	not considered
Partial Stroke Test Coverage	PSTC	not considered

Note

The Safe Failure Fraction (SFF) was estimated by an alternative method with a FMEDA according to EN161:2011/A3:2013.

Derived Values for 1oo1-Architecture

Assumed Demands per Year	f_{np}	1 / a	1.14 E-04 / h
Total Failure Rate	$\lambda_S + \lambda_D$	4.13 E-07 / h	413 FIT
Lambda Dangerous Detected	λ_{DD}	0.00 E+00 / h	0 FIT
Lambda Dangerous Undetected	λ_{DU}	2.07 E-08 / h	21 FIT
Lambda Safe Detected	λ_{SD}	0.00 E+00 / h	0 FIT
Lambda Safe Undetected	λ_{SU}	3.93 E-07 / h	393 FIT
Mean Time Between Failures	MTBF	2.42 E+06 h	276 a
Mean Time Between Dangerous Failures	MTBF _D	4.84 E+07 h	5526 a
Average Probability of Failure on Demand	PFD_{avg}	9.05 E-05	

Time of Usage

A time of usage of more than 5 years (+ 1.5 years of storage) can only be favored under responsibility of the operator, consideration of specific external conditions (securing of required quality of media, max. temperature, time of impact), and adequate test cycles.

Quality Management

These statements are bound to a proven and verified deployment of safety-related quality management of the manufacturer.