

# Certificate



SIL/PL  
Capability

www.tuv.com  
ID 0600000000

**No.: V 485.01/15**

<b>Product tested</b>	Hydraulic quarter turn and linear actuators	<b>Certificate holder</b>	Emerson Process Management Damcos A/S Aederupvej 41 4700 Naestved Denmark
<b>Type designation</b>	Quarter turn actuators: BRC - double acting, BRCF (HT) - single acting Linear actuators: KC - double acting, KF/KFR - single acting		
<b>Codes and standards</b>	IEC 61508 Parts 1-2 and 4-7:2010	IEC 61511 Parts 1-3:2004 (in extracts)	
<b>Intended application</b>	The actuators are suitable for use in a safety instrumented system up to SIL 2. Under consideration of the minimum required hardware fault tolerance HFT=1 the actuators may be used in a redundant structure up to SIL 3.		
<b>Specific requirements</b>	The instructions of the associated Installation, Operating and Safety Manual have to be considered.		

Summary of test results see back side of this certificate.

Valid until 2020-05-20

The issue of this certificate is based upon an examination, whose results are documented in Report No. V 485.01/15 dated 2015-05-20.

This certificate is valid only for products which are identical with the product tested. It becomes invalid at any change of the codes and standards forming the basis of testing for the intended application.

**TÜV Rheinland Industrie Service GmbH**

Bereich Automation  
Funktionale Sicherheit

Am Grauen Stein, 51105 Köln

Köln, 2015-05-20

Certification Body for FS-Products

Dipl.-Ing. Stephan Häb

www.fs-products.com  
www.tuv.com

**TÜVRheinland**<sup>®</sup>  
Precisely Right.

Manufacturer	<b>Emerson Process Management</b> <b>Damcos A/S</b> <b>Aederupvej 41,</b> <b>DK-4700 Naestved</b>	<b>Emerson Process Management Marine Solutions Co., Ltd</b> <b>530, Sinpyeong-dong Saha-gu</b> <b>Busan, 604-836</b> <b>Korea</b>
--------------	--	--

Product tested **Hydraulic Actuators BRC, BRCF (HT), KC, KF(R)**

Device specific values		BRC, BRCF(HT)	KC; KF(R)
Probability of Dangerous Failure on Demand	$PFD_{spec}$	2,46 E-04	1,97 E-04
Assumed Test Interval	$T_i$	1 a	1 a
Confidence Level	$1-\alpha$	95 %	95 %
Safe Failure Fraction <sup>(see note)</sup>	SFF	72 %	67 %
Hardware Fault Tolerance	HFT	0	0
Diagnostic Coverage	DC	0 %	0 %
Type of Sub System		Typ A	Typ A
Mode of Operation		Low Demand	Low Demand
Proof Test Coverage	PTC	75 %	85 %
Partial Stroke Test Coverage	PSTC	Not considered	Not considered

#### Note

The Safe Failure Fraction (SFF) was estimated by an alternative method with a FMEA according to EN 161:2011/A3:2013.

Derived Values for 1oo1-Architecture		BRC, BRCF(HT)		KC; KF(R)	
Assumed Demands per Year	$f_{np}$	1 / a		1 / a	
Total Failure Rate	$\lambda_S + \lambda_D$	1,00 E-07 / h	100 FIT	6,82 E-08 / h	68 FIT
Lambda Dangerous Detected	$\lambda_{DD}$	0,00 E+00 / h	0 FIT	0,00 E+00 / h	0 FIT
Lambda Dangerous Undetected	$\lambda_{DU}$	2,81 E-08 / h	28 FIT	2,25 E-08 / h	22 FIT
Lambda Safe	$\lambda_S$	7,23 E-08 / h	72 FIT	4,57 E-08 / h	46 FIT
Mean Time Between Failures	MTBF	9,96 E+06 h	1.137 a	1,47 E+07 h	1.675 a
Mean Time Between Dangerous Failures	MTBF <sub>D</sub>	3,56 E+07 h	4.060 a	4,45 E+07 h	5.074 a
<b>Average Probability of Failure on Demand</b>	<b>PFD<sub>avg</sub></b>	<b>1,23 E-04</b>		<b>9,85 E-05</b>	

#### Time of Usage

A time of usage of more than 5 years (+ 1.5 years of storage) can only be favored under responsibility of the operator, consideration of specific external conditions (securing of required quality of media, max. temperature, time of impact), and adequate test cycles.

#### Quality Management

These statements are bound to a proven and verified deployment of safety-related quality management of the manufacturer.