

# Certificate



Product Safety  
SIL/PL  
Capability

www.tuv.com  
ID 060000000

**No.: 968/EZ 511.01/16**

<b>Product tested</b>	3300 XL Proximity Transducer System	<b>Certificate holder</b>	BENTLY NEVADA Corp. 1631 Bently Parkway South Minden, NV 89423 USA
-----------------------	-------------------------------------	---------------------------	---

<b>Type designation</b>	330780-Axx-Bxx, 330180-Axx-Bxx
-------------------------	-----------------------------------

<b>Codes and standards</b>	IEC 61508 Parts 1-7:2010 (in extracts)	EN 61326-2-3:2006
----------------------------	--	-------------------

<b>Intended application</b>	The 3300 XL Proximity Transducer System can be used within the Bently Nevada Monitoring System (e.g. 3500/40 or 3500/42M Monitor Modules) for monitoring of vibration and position on machines in safety applications up to SIL 2 acc. to IEC 61508. Prerequisite is the implementation of a diagnostic in the monitoring device to detect signals out of range as a failure condition.
-----------------------------	---

<b>Specific requirements</b>	The instructions of the associated Installation and Operating Manual shall be considered.
------------------------------	---

Valid until 2021-06-27

The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/EZ 511.01/16 dated 2016-06-27.

This certificate is valid only for products which are identical with the product tested. It becomes invalid at any change of the codes and standards forming the basis of testing for the intended application.

**TÜV Rheinland Industrie Service GmbH**  
Bereich Automation  
Funktionale Sicherheit  
Am Grauen Stein, 51105 Köln

Köln, 2016-06-27

Certification Body Safety & Security for Automation & Grid

Dipl.-Ing. Heinz Gall