

Certificate



Functional
Safety

www.tuv.com
ID 060000000

No.: 968/FSP 1522.00/17

Product tested	Fire & Gas Central Unit	Certificate holder	Consilium Control Systems AS Holskogveien 48 4624 Kristiansand Norway
-----------------------	-------------------------	---------------------------	--

Type designation	ConSafe, consisting of modules see attached "Revision List"
-------------------------	--

Codes and standards	IEC 61508 Parts 1-7:2010
----------------------------	--------------------------

Intended application	The system complies with the requirements of the relevant standards (SIL 2 in "mono" configuration and SIL 3 in "duplex" configuration according to IEC 61508) and can be used in applications up to SIL 2 resp. SIL 3 of IEC 61508 depending on the configuration.
-----------------------------	---

Specific requirements	The instructions of the associated Installation, Operating Manual and Safety Manual shall be considered.
------------------------------	--

Valid until 2018-11-11

The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/FSP 1522.00/17 dated 2017-11-07.

This certificate is valid only for products which are identical with the product tested. It becomes invalid at any change of the codes and standards forming the basis of testing for the intended application.

TÜV Rheinland Industrie Service GmbH
Bereich Automation
Funktionale Sicherheit
Am Grauen Stein, 51105 Köln

Köln, 2017-11-07

Certification Body Safety & Security for Automation & Grid

Dipl.-Ing. Stephan Häb

www.fs-products.com
www.tuv.com

TÜVRheinland
Precisely Right.