

Certificate



No.: 968/FSP 1705.00/18

Product tested Magnetostrictive Liquid Level Transmitter **Certificate holder** Clark-Reliance
16633 Foltz Parkway
Strongsville, OH 44149
USA

Type designation Jerguson MTII-4300

Codes and standards IEC 61508 Parts 1-7:2010

Intended application The Magnetostrictive Liquid Level Transmitter complies with the requirements of the relevant standards (Hardware safety integrity SIL 2) and can be used in applications up to SIL 2 (HFT=0) at a measurement accuracy of 2%.
The product was also reviewed for the use in the application area of IEC 61511-1 up to SIL 2.

Specific requirements The instructions of the associated Operating and Safety Manual shall be considered.

Valid until 2022-11-22


The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/FSP 1705.00/18 dated 2018-08-08.

This certificate is valid only for products which are identical with the product tested.

TÜV Rheinland Industrie Service GmbH
Bereich Automation
Funktionale Sicherheit
Am Grauen Stein, 51105 Köln

Köln, 2018-08-08

Certification Body Safety & Security for Automation & Grid


Dipl.-Ing. Gebhard Bouwer