

Certificate



No.: 968/EL 984.03/19

Product tested	Safety Protocol Specification	Certificate holder	CC-Link Partner Association 6F Ozone-front Bldg. 3-15-58, Ozone Kita-Ku Nagoya 462-0825 Japan
-----------------------	-------------------------------	---------------------------	---

Type designation	CC-Link IE Safety Communication Function Specification (Document ID: BAP-C2007ENG-002, Rev. B)		
-------------------------	---	--	--

Codes and standards	IEC 61508 Parts 1-7:2010	IEC 61784-3:2016+A1:2017 (in extracts)
----------------------------	--------------------------	--

Intended application	The CC-Link IE Safety Protocol Specification, protocol version 2, fulfills all respective requirements of the IEC 61508 for the safety level SIL 3 and in extracts of the IEC 61784-3. A safety protocol in accordance with this specification can be used in safety communication systems up to SIL 3.		
-----------------------------	---	--	--

Specific requirements	The instructions and specific requirements of the CC-Link IE Safety Protocol Specification as well as the restrictions in chapter 4.3 of the related test report No. 968/EL 984.03/19 shall be considered.		
------------------------------	--	--	--


Valid until 2024-03-29

The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/EL 984.03/19 dated 2019-03-29.
This certificate is valid only for products which are identical with the product tested.

TÜV Rheinland Industrie Service GmbH
Bereich Automation
Funktionale Sicherheit
Am Grauen Stein, 51105 Köln

Köln, 2019-03-29

Certification Body Safety & Security for Automation & Grid


Dipl.-Ing. Gebhard Bouwer