

Certificate



Functional
Safety

www.tuv.com
ID 0600000000

No.: 968/FSP 1262.02/19

Product tested "Safe Torque Off" (STO) within DG1 and DH1 series AC drive of Eaton Corporation
Certificate holder Eaton Corporation
W126N7250 Flint Drive
Menomonee Falls, WI
53051
USA

Type designation DG1 and DH1 Series Frame Size FR1-FR6 (Voltage rating = 5, or EMC filter = D, E or N)
Details see actual "Revision List"

Codes and standards IEC 61800-5-2:2016 ISO 13849-1:2015
EN 61800-5-1:2007 (in extracts) IEC 61508 Parts 1-7:2010
IEC 61800-3:2017 (in extracts) IEC 60204-1:2016 (in extracts)
IEC 62061:2015

Intended application The safety function STO complies with the requirements of the relevant standards (Cat. 1 / PL c acc. to ISO 13849-1, SIL 1 / SIL CL 1 acc. to IEC 61800-5-2 / IEC 62061 / IEC 61508) and can be used in applications up to these safety levels

Specific requirements The instructions of the associated Installation and Operating Manual shall be considered.

Valid until 2020-04-28

The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/FSP 1262.02/19 dated 2019-01-08.

This certificate is valid only for products which are identical with the product tested.

TÜV Rheinland Industrie Service GmbH
Bereich Automation
Funktionale Sicherheit
Am Grauen Stein, 51105 Köln

Köln, 2019-01-08

Certification Body Safety & Security for Automation & Grid

Dipl.-Ing. Thomas Steffens

www.fs-products.com
www.tuv.com

TÜVRheinland
Precisely Right.