

Certificate



SIL/PL
Capability

www.tuv.com
ID 0600000000

No.: 968/V 1124.00/19

Product tested	Ball Valves	Certificate holder	Burkert UK Limited Fluid Control Centre, 1 Bridge End, Cirencester GL7 1QY, United Kingdom
Type designation	2651-107S 2651-201D, 2651-207F, 2651-207S 2654-302F, 2654-302S, 2654-305D, 2654-306D		(1-piece type) (2-pieces type) (3-pieces type)
Codes and standards	IEC 61508 Parts 1-2 and 4-7:2010		
Intended application	Safety Function: Fail-Close or Fail-Open The valves are suitable for use in a safety instrumented system up to SIL 2 (low demand mode). Under consideration of the minimum required hardware fault tolerance HFT = 1 the valves may be used in a redundant architecture up to SIL 3 acc. to IEC 61508 and IEC 61511.		
Specific requirements	The instructions of the associated Installation, Operating and Safety Manual shall be considered.		

Summary of test results see back side of this certificate.

Valid until 2024-01-30


The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/V 1124.00/19 dated 2019-07-10.

This certificate is valid only for products which are identical with the product tested.

TÜV Rheinland Industrie Service GmbH
Bereich Automation
Funktionale Sicherheit
Am Grauen Stein, 51105 Köln

Köln, 2019-07-10

Certification Body Safety & Security for Automation & Grid


Dipl.-Ing. Gebhard Bouwer

www.fs-products.com
www.tuv.com

 **TÜVRheinland®**
Precisely Right.

Holder: Burkert UK Limited
 Fluid Control Centre, 1 Bridge End,
 Cirencester GL7 1QY,
 United Kingdom

Product tested: Ball Valves
 2651-107S (1-piece type)
 2651-201D, 2651-207F, 2651-207S (2-pieces type)
 2654-302F, 2654-302S, 2654-305D, 2654-306D (3-pieces type)

Result of Assessment

Route of Assessment		2 _H / 1 _s	
Type of Sub-system		Type A	
Mode of Operation		Low Demand Mode	
Hardware Fault Tolerance	HFT	0	
Lambda Dangerous confidence level of calculation 1- α = 95%	λ_D	2,58 E-07 / h	258FIT
Lambda Dangerous Undetected assumed Diagnostic Coverage DC = 0%	λ_{DU}	2,58 E-07 / h	258FIT
Average Probability of Failure on Demand 1oo1 assumed Proof Test Interval $T_1 = 1$ year	PFD_{avg}(T₁)	1,13E-03	
Average Probability of Failure on Demand 1oo2 assumed Proof Test Interval $T_1 = 1$ year assumed $\beta_{1oo2} = 10\%$	PFD_{avg}(T₁)	1,15E-04	

Origin of values

The stated values are the results of evaluation of qualification test on the reliability of the safety function under critical conditions. Random and systematic failures which are the responsibility of the manufacturer were examined.

Systematic Capability

The development and manufacturing process and the functional safety management applied by the manufacturer in the relevant lifecycle phases of the product have been audited and assessed as suitable for the manufacturing of products for use in applications with a maximum Safety Integrity Level of 3 (SC 3).

Periodic Tests and Maintenance

The given values require periodic tests and maintenance as described in the Safety Manual. The operator is responsible for the consideration of specific external conditions (e.g. ensuring of required quality of media, max. temperature, time of impact), and adequate test cycles.