

# Certificate



Functional  
Safety

www.tuv.com  
ID 060000000

**No.: 968/FSP 1613.00/20**


<b>Product tested</b>	Functional Safety I/O Module with ProfiSafe	<b>Certificate holder</b>	ASSA ABLOY Entrance Systems AB Lodjursgatan 10 261 44 Landskrona Sweden
<b>Type designation</b>	RapidProtect PROFIsafe (Details see Revision List)		
<b>Codes and standards</b>	EN ISO 13849-1:2015 EN 62061:2005 + AC:2010 + A1:2013 + A2:2015	EN 61508 Parts 1-7:2010	
<b>Intended application</b>	The safety related functions "Read digital inputs" and "Set digital outputs" as well the ProfiSafe protocol functionality within the RapidProtect PROFIsafe comply with the requirements of the relevant standards (Cat. 4 / PL e acc. to EN ISO 13849-1, SILCL 3 / SIL 3 acc. to EN 62061 / EN 61508).  Further the "Control of the emergency stop input of MCC controllers" complies with the requirements of the relevant standards (Cat. 3 / PL d acc. to EN ISO 13849-1, SILCL 2 / SIL 2 acc. to EN 62061 / EN 61508).		
<b>Specific requirements</b>	The instructions of the associated User Manual shall be considered.		
<b>Valid until</b>	2025-11-11		

The issue of this certificate is based upon an evaluation in accordance with the Certification Program CERT FSP1 V1.0:2017 in its actual version, whose results are documented in Report No. 968/FSP 1613.00/20 dated 2020-11-11. This certificate is valid only for products, which are identical with the product tested.

**TÜV Rheinland Industrie Service GmbH**  
Bereich Automation  
Funktionale Sicherheit  
Am Grauen Stein, 51105 Köln

Köln, 2020-11-11

Certification Body Safety & Security for Automation & Grid

  
Dipl.-Ing. Gebhard Bouwer