

Certificate



SIL/PL
Capability

www.tuv.com
ID 0600000000

No.: 968/V 1211.00/21

Product tested Redundant Safety Exhaust Valves **Certificate holder** ASCO L.P.
46280 Dylan Drive Novi MI 48377 USA

Type designation Series 652 / 653

Codes and standards ISO 13849-1:2015 ISO 13849-2:2012

Intended application The safety function "safe release of pressure" of the quick exhaust valve series 652 / 653 fulfils the intended requirements for PL d / Category 3 according to ISO 13849-1.

Specific requirements The instructions of the associated Installation, Operating and Safety Manual shall be considered.

Valid until 2026-01-14


The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/V 1211.00/21 dated 2021-01-13.

This certificate is valid only for products which are identical with the product tested.

TÜV Rheinland Industrie Service GmbH
Bereich Automation
Funktionale Sicherheit

Köln, 2021-01-14

Certification Body Safety & Security for Automation & Grid


Dipl.-Ing. (FH) Wolf Rückwart