

# Certificate



**No.: 968/EL 984.06/22**

<b>Product tested</b>	Safety Protocol Specification	<b>Certificate holder</b>	CC-Link Partner Association 6F Ozone-front Building 3-15-58, Ozone Kita-Ku Nagoya 462-0825 Japan
-----------------------	-------------------------------	---------------------------	--

<b>Type designation</b>	CC-Link IE Safety Communication Function Specification Document ID: BAP-C2007ENG-002, Rev. C, dated 2022-03-10
-------------------------	---

<b>Codes and standards</b>	IEC 61508-2:2010 (clause 7.4.11)    IEC 61784-3:2021
----------------------------	--

<b>Intended application</b>	The CC-Link IE Safety Communication Function Specification, protocol version 2, fulfills all respective requirements of the IEC 61508-2, clause 7.4.11 for the safety level SIL 3 and IEC 61784-3. A safety protocol in accordance with this specification can be used in safety communication systems up to SIL 3.
-----------------------------	---

<b>Specific requirements</b>	The instructions and specific requirements of the CC-Link IE Safety Communication Function Specification as well as the restrictions in chapter 4.3 and summary of the related test report No. 968/EL 984.06/22 shall be considered.
------------------------------	--

Valid until 2027-03-24


The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/EL 984.06/22 dated 2022-03-24.

This certificate is valid only for products which are identical with the product tested.

**TÜV Rheinland Industrie Service GmbH**  
Bereich Automation  
Funktionale Sicherheit  
Am Grauen Stein, 51105 Köln

Köln, 2022-03-24

Certification Body Safety & Security for Automation & Grid

  
Dipl.-Ing. Gebhard Bouwer