

Nomenclature of the Emergency Stop Module SAFEMASTER LG 5925

Example:	LG 5925	<u>.##</u>	<u>##</u> /	<u>##</u>	<u>###</u>	<u>/##</u>	<u>#####</u>
		I	II	III	IV	V	VI
I Output contact configuration	.02	2 NO dry contact control outputs					
	.03	3 NO dry contact control outputs, 1 NC dry contact monitoring output					
	.04	4 NO dry contact control outputs					
	.48	3 NO dry contact control outputs, 1 NC dry contact monitoring output					
	.54	3 NO dry contact control outputs, 1 NC dry contact output, 1 semiconductor monitoring output					
II Terminal type	<none>	fixed screw clamp					
	PC	plug in cage clamp					
	PS	plug in screw clamp					
III Optional customized labeling	Up to two customer specific characters for OEM identification						
IV Device configuration	000 or <none> for use with emergency stop switches, safety switches or position switches						
	900 for use with suitable light curtains						
	920 for use with suitable safety switches						
V Optional	/60.../69 Identification for additional licenses, e.g. CSA (/60), UL (/61), Germanischer Lloyd (/66)						
VI Power supply voltage	DC24V, AC/DC24V, AC/DC110-115V, AC230V						

Safety related modules / components

No.	Type Designation	Description	Power supply voltages	Report-No.:	Certification Status
1	LG 5925.02	Emergency stop module for use with emergency stop switches, door switches or position switches	AC/DC 24 V AC/DC 110-115 V AC 230 V	968/EZ 432.04/16	Valid
2	LG 5925.03			968/EZ 432.04/16	Valid
3	LG 5925.04			968/EZ 432.04/16	Valid
4	LG 5925.48			968/EZ 432.04/16	Valid

No.	Type Designation	Description	Power supply voltages	Report-No.:	Certification Status
5	LG 5925.54	Emergency stop module for use with emergency stop switches, door switches or position switches	AC/DC 24 V	968/EZ 432.04/16	Valid
6	LG 5925.02/900	Emergency stop module for use with suitable light curtains	DC 24 V	968/EZ 432.04/16	Valid
7	LG 5925.04/900			968/EZ 432.04/16	Valid
8	LG 5925.48/900			968/EZ 432.04/16	Valid
9	LG 5925.02/920	Emergency stop module for use with suitable safety switches	DC 24 V	968/EZ 432.04/16	Valid
10	LG 5925.04/920			968/EZ 432.04/16	Valid
11	LG 5925.48/920			968/EZ 432.04/16	Valid

User documentation

c.f. No.	Document-No. / Issue	Description	Report-No.:	Certification Status
1 - 5	151124 / 615	Operating Instructions LG 5925.xx	968/EZ 432.04/16	Valid
6 - 8	151124 / 615	Operating Instructions LG 5925.xx/900	968/EZ 432.04/16	Valid
9 - 11	151124 / 615	Operating Instructions LG 5925.xx/920	968/EZ 432.04/16	Valid

The Revision List has been jointly agreed between the manufacturer and the Test Institute.

Revision:

Date	Rev.	Description / Changes	Author
2015-11-02	1.0	Initial creation, based on Report-No.: 968/EZ 432.03/15	bwk/A-FS
2015-11-26	1.1	Section User documentation – update of Document-No. / Issue and Certification Status	bwk/A-FS
2016-09-22	1.2	Reissue of the certificate	jmu/A-FS