

EC Type-Examination Certificate



Product Safety
Functional
Safety

www.tuv.com
ID 0600000000


Reg.-No.: 01/205/5557.01/21

Product tested	Safety relay unit for emergency stop applications	Certificate holder	DINKLE ENTERPRISE CO., LTD. No.19, Wuquan 2nd Rd., Wugu District, TW-248020 New Taipei City, Taiwan
Type designation	RESR-01-3A1B, RESR-01-3A1B-S, RESR-11-2A2B-P, RESR-11-2A2B-PS, RESR-01-2A2B, RESR-01-2A2B-S, RESR-01-3A1BM, RESR-01-3A1BM-S, RESR-11-3A1B-P, RESR-11-3A1B-PS, RESR-01-2A2BM, RESR-01-2A2BM-S		
Codes and standards	ISO 13849-1:2015 IEC 62061:2015	IEC 61508 Parts 1-7:2010	
Intended application	Safety relay unit for emergency stop applications: The safety relay unit complies with the requirements of relevant standards (Cat.4 / PL e acc. to ISO 13849-1, SIL 3 / SIL CL 3 acc. to IEC62061 / IEC 61508) and can be used in applications up to PL e acc. to ISO 13849-1 and SIL 3 acc. to IEC 62061 / IEC 61508.		
Specific requirements	The instructions of the associated Installation, Operating and Safety Manual shall be considered.		

It is confirmed, that the product under test complies with the requirements for machines defined in Annex I of the EC Directive 2006/42/EC.

Valid until 2024-05-06

The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/FSP 1383.01/21 dated 2021-03-15.
This certificate is valid only for products which are identical with the product tested.



Köln, 2021-03-15

Notified Body for Machinery, NB 0035

Jelena Stenzel
Dipl.-Ing. Jelena Stenzel