

UK Type-Examination Certificate



For UK Regulations SI 2008 No. 1597
The Supply of Machinery Regulations 2008

Reg.-No.: 01/205U/0605.00/22

Product tested	Emergency Stop Safety Modules	Certificate holder	Banner Engineering Corp. 9714 Tenth Avenue North Minneapolis, MN 55441 USA
Type designation	ES-FA-9AA, ES-FA-11AA, UM-FA-9A, UM-FA-11A		
Codes and standards	EN 62061:2005 + AC:2010 + A1:2013 + A2:2015 EN ISO 13849-1:2015	IEC 61508 Parts 1-7:2010	
Intended application	The devices can be used in applications up to SIL 3 / SIL CL 3 acc. to IEC 61508 / IEC 62061 and Category 4, PL e acc. to EN ISO 13849-1.		
Specific requirements	The instructions of the associated Installation and Operating Manual shall be considered.		

This product is in conformity with all requirements of SCHEDULE 2, PART 1 (Annex I) of SI 2008 No. 1597.

This Type-Examination certificate refers to an evaluation of the above mentioned product as stipulated in SCHEDULE 2, PART 9 (Annex IX) of SI 2008 No. 1597.

Valid until 2024-10-28


The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/EL 594.03/22 dated 2022-06-28.

This certificate is valid only for products which are identical with the product tested.

Köln, 2022-06-28

TUV Rheinland UK Ltd.

Approved Body for Machinery, No. 2571


Dipl.-Ing. Gebhard Bouwer